



सत्यमेव जयते

GOVT. OF ASSAM  
OFFICE OF THE DIRECTOR  
FIRE & EMERGENCY SERVICES,  
GUWAHATI

ASSAM

Form - G



UBIN : 302/83702/AACAC8986C/3/2023

UAIN : FNESBNOCI/2023/00681

NO OBJECTION CERTIFICATE OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN APPLICATION FOR FIRE NOC FOR ONE STORIED / MULTI-STORIED / HIGH RISE BUILDING UNDER ASSAM FIRE SERVICE RULE 1989 (FORM NO I)

Hazard Category: **Moderate Hazard**

This NOC is issued to **COLLEGE OF TEACHER EDUCATION TINSUKIA** on **19/05/2023** with reference to Compliance Report No. **Nil** dated **08/05/2023**

I here by certify that the building as per description below at **Dag No. 428 Patta No. 213 (34 OLD) Mouza RANGAGORA Place DAHOTIA CHUK , TINSUKIA** has been inspected in respect of implementation of inbuilt Fire Fighting, Fire Prevention and Means of escape measures and is declared fit in respect of fire safety. The Fire & Emergency Services, Assam has no objection in its occupation/ utilization for the purpose of:

DETAILS OF APPROVED OCCUPATION

S. No.	Floor	Floor Area	Purpose of Utilization
1.	GROUND FLOOR	220 SQM	OFFICE, COMMON ROOM, CLASS ROOM ETC.
2.	FIRST FLOOR	233 SQM	CLASS ROOM, LABORATORY, LIBRARY
3.	SECOND FLOOR	233 SQM	HALL

THIS NOC IS VALID UP TO 18/5/2025

Place of issue : **GUWAHATI**

Date of issue : **19/05/2023**

Director of Fire and Emergency Services,  
Guwahati, Assam

(Subject to Conditions mentioned here under)

CONDITIONS :

1. There should not be any change of Trade for which this License has been issued.
2. There should not be any structural change in the building either horizontally or vertically. There should not also be any change in the existing arrangements.
3. The fire fighting equipments should be in serviceable condition at all time

4. Water reservoir should always be kept full up to brim
5. The entrance and exit and the water reservoir should always be free from any obstruction/projection.
6. The NOC is liable to be cancelled if the premises (for which the NOC is granted) when inspected are not found conforming to the description and condition under which this NOC is granted.

Director of Fire and Emergency  
Services,  
Guwahati, Assam



Note : This certificate is computer generated and does not require any Seal/Signature.